



Number	64606/02	Replaces	64606/01
Issued	01/10/2023	Scope	AR 69
Contract number	Q00/011	Page	1-2

Product Certificate

Connection valve type RAM

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

Raminex International B.V.

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 69, for "Metal connection taps and laboratory taps for installations inside buildings", dated October 2021.

Ron Scheepers
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Kiwa Nederland B.V.
Sir. Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel.+31 88 998 4400
info@kiwa.nl
www.kiwa.nl

supplier
RAMINEX International B.V.
Landzigt 34
3454 PE Utrecht
The Netherlands

www.raminex.nl

T +31 (0)30 241 12 24



CERTIFICATE

Number	64606/02	Replaces	64606/01
Issued	01/10/2023	Scope	AR 69
Contract number	Q00/011	Page	2-2

Connection valve type RAM

PRODUCT SPECIFICATION

Connection valve (Ball valve) type RAM
Maximum operating pressure 200 mbar
Provided with a locking control handle
Connection inlet side: outer tread R ½"
Connection outlet side: M24 x 1.5
Straight and angled version

APPLICATION AND USE

Metal connection taps and laboratory taps for gas installations in buildings and residences (behind the meter) in accordance with the scope of NEN 1078 or NEN 8078, up to a maximum operating pressure of 200 mbar at temperatures between -5°C and 70°C for the use of gases from the 2nd and 3rd families according to EN 437 with connection dimensions from DN 10 up to and including DN 50.

MARKING

- GASTEC QA, GASTEC QA logo or punch mark
 - The name of the manufacturer or their trademark;
 - The nominal pass DN;
 - If necessary, the flow direction by means of an arrow.
-

RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.
